

IMPACT TEST 4mm

TESTING AUTHORITY	ENGTEST
TEST	AS 1562.3:1996
TEST NUMBERS	C971001 / C971201
DATES	Nov/Dec 1997

SHEETING DETAIL

Danpalon DP4 Solid polycarbonate, 4mm thick, 600mm wide.

FASTENING TO PURLINS

Purlin Spacing	800mm / 1000mm / 800mm
Maximum Overhang	50mm
Fixing	DP4 Spacer fixed at every purlin

FASTENING TO RAFTERS ONLY

Sheet Length	Up to 12 metres
Transverse Support	Fascia board at each end only
Maximum Overhang	50mm
Fixing	

1. DP4 spacer fixed at 1000mm centres.
2. Edge sheet to be fixed to outside rafter with 12g x 50mm Tek screws and 25mm climaseal washers. Spacing as per knee fasteners. Screw holes must be oversize to facilitate expansion. Screws are then covered with metal barge flashing.

RESULT

**DANPALON DP4 MEETS THE REQUIREMENTS OF THIS TEST
THUS ELIMINATING THE NEED FOR SAFETY MESH**